

**E-WATERTEST.COM
33 Third Street, Suite 102
Bordentown, NJ 08505**

Laboratory - 609-291-9072

Corporate Office - 609-298-8471

Dear E-WaterTest Client;

Enclosed please find your comprehensive Priority 150 Water Test report.

We have prepared the report with the consumer in mind, taking special care to provide an informative, yet simple to understand format. If you would like a printed copy of the report, please select the print option on your internet browser window.

The USEPA has designated a “Limit” or “Maximum Contaminant Level” for most parameters included in the Priority 150 Water Test. However, there are some parameters, particularly in the VOC category, that have not as yet been assigned “MCL’s”. If a parameter has an “MCL”, it will be shown in the column immediately to the right of that parameter.

If you have any additional questions concerning your report, you can visit the website, or you can e-mail me directly at the e-mail address listed below.

Please remember that the Priority 150 is intended to be for personal informational purposes only and not intended to be used for legal or regulatory compliance matters. If a primary parameter located in the VOC section exceeds the USEPA limit, you may wish to retest the source at a local certified laboratory to confirm its presence.

We hope that you have found the Priority 150 Water Test to be helpful in determining the quality of your drinking and bathing water and hope that we can be of service to many of your family and friends.

Thank You again for your trust in using E-WATERTEST.COM.

**D. B. Lilley
President/CEO**

dblilley@e-watertest.com

E-WATERTEST.COM
“Using Only USEPA Approved Testing Methods”
www.e-watertest.com
609-291-9072

Sample Report
123 Park Place
Atlantic City, NJ 12345

Date Collected: **12-20-08**
Time Collected: **8:00am**

Matrix: **Water**
Source: **Public System**
Collected by: **Owner**
EWT Sample #: **E-7959-1220-08**

Parameter	MCL(mg/L)	Result(mg/L)
Total Coliform Bacteria	<1/100ml (absent)	0/100ml (absent)
E. Coli Bacteria	<1/100ml (absent)	0/100ml (absent)
Iron	0.30	0.25
Manganese	0.05	<0.01
Lead	0.010	<0.001
Mercury	0.002	<0.0002
Sodium	50.0	63.78
Arsenic	0.010	<0.001
pH	6.5-8.5	6.98
Nitrate	10.0	0.36
Hardness (CaCO3)	250.0	92.80

All testing performed using USEPA approved testing methods

MCL = Maximum Contaminant Level > = greater than < = less than
mg/L = ppm (parts per million)

Remarks:

All parameters tested, except sodium, meet the requirements established by the USEPA.

Note: Actual pH measurement may be slightly lower or higher than result reported due to transit time of sample.

Note: Report is intended to be used for informational purposes only and should not be used for regulatory and/or legal purposes.

Report Date: **January 2, 2009**

By: **Thomas J. Mullen**
Laboratory Director

E-WATERTEST.COM

www.e-watertest.com

609-291-9072

Number/Name: E-7959/Sample ReportMatrix: **Water** Collected by: **Owner** Analysis: **Pesticides/PCB's**

Parameter/Method EPA 505	MDL (ug/L)	Result (ug/L)
PCB 1262	0.190	nd
PCB 1260	0.160	nd
PCB 1254	0.110	nd
PCB 1248	0.089	nd
PCB 1242	0.140	nd
PCB 1232	0.170	nd
PCB 1221	0.790	nd
PCB 1061	0.050	nd
a-BHC	0.001	nd
b-BHC	0.001	nd
g-BHC	0.001	nd
alachlor	0.160	nd
aldrin	0.002	nd
atrazine	0.260	nd
dieldrin	0.008	nd
endrin	0.027	nd
heptachlor	0.001	nd
heptachlor epox	0.002	nd
hexachlorobenzene	0.001	nd
hexachlorocyclopentadiene	0.006	nd
lindane	0.001	nd
methoxychlor	0.310	nd
simazine	0.870	nd
c-nonachlor	0.009	nd
t-nonachlor	0.007	nd
DDD	0.210	nd
DDT	0.170	nd
DDE	0.130	nd
endosulfan I	0.180	nd
endosulfan II	0.210	nd
endrin aldehyde	0.170	nd
endosulfan sulfate	0.260	nd
chlordane	0.100	nd
toxaphene	0.780	nd

MCL = Maximum Contaminant Level **MDL** = Minimum Detection Level**nd** = none detected **ug/L = ppb** (parts per billion) * - Closest MatchReport Date: **January 2, 2009**

E-WATERTEST.COM

www.e-watertest.com

609-291-9072

Number/Name: E-7959/Sample Report

Matrix: **Water**

Collected by: **Owner**

Analysis: **Volatile Organic Compounds**

Parameter/Method	MCL	MDL	Result
VOC/EPA 524.2	(ug/L)	(ug/L)	(ug/L)
Acetone		0.400	nd
Acrylontrile		0.490	nd
Allyl Chloride		0.480	nd
2-Butanone		0.350	nd
Carbon Disulfide		0.370	nd
Chloroacetone		0.380	nd
Trans-1,2-Dichloroethene		0.330	nd
1,1-Dichloropropanone		0.330	nd
Diethylether		0.480	nd
Ethyl Methacrylate		0.430	nd
Hexachloroethane		0.390	nd
2-Hexanone		0.380	nd
Methacrylonitrile		0.320	nd
Methylacrylate		0.320	nd
Methyliodide		0.530	nd
Methylmethacrylate		0.430	nd
4-Methyl-2-Pentanone		0.450	nd
Nitrobenzene		0.260	nd
2-Nitropropane		0.350	nd
Pentachloroethane		0.180	nd
Propionitrile		0.420	nd
1-Chlorobutane		0.440	nd
Dichloroflouromethane		0.360	nd
Chloromethane		0.300	nd
Vinyl Chloride	2	0.250	nd
Bromomethane		0.250	nd
Chloroethane		0.290	nd
Trichlorofluoromethane		0.270	nd

Parameter/Method VOC/EPA 524.2	MCL (ug/L)	MDL (ug/L)	Result (ug/L)
1,1 Dichloroethene	2	0.330	nd
Methylene Chloride	3	0.320	nd
trans-1,2-Dichloroethene	100	0.330	nd
1,1 Dichloroethane	50	0.260	nd
2,2 Dichloropropane		0.350	nd
cis-1,2 Dichloroethene	70	0.240	nd
Chloroform		0.240	1.03ppb
Bromochloromethane		0.460	nd
1,1,1 Trichloroethane	30	0.210	nd
1,1 Dichloropropene		0.440	nd
Carbon Tetrachloride	2	0.340	nd
Benzene	1	0.220	nd
1,2 Dichloroethane	2	0.370	nd
Trichloroethene	1	0.360	nd
1,2 Dichloropropane	5	0.240	nd
Bromodichloromethane		0.310	nd
Dibromomethane		0.120	nd
cis-1,3 Dichloropropene		0.230	nd
Toluene	1000	0.150	nd
trans-1,3 Dichloropropene		0.280	nd
1,1,2 Trichloroethane	3	0.290	nd
Tetrachloroethene	1	0.200	nd
1,3 Dichloropropane		0.250	nd
Dibromochloromethane		0.290	2.18ppb
1,2 Dibromomethane		0.130	nd
Chlorobenzene	50	0.230	nd
Ethylbenzene	700	0.220	nd
1,1,1,2 Tetrachloroethane	1	0.180	nd
m,p-Xylene		0.440	nd
o-Xylene		0.350	nd
Styrene	100	0.380	nd
Methyl Tertiary Butyl Ether (MTBE)	70	0.290	nd
Isopropylbenzene		0.290	nd
Bromoform		0.280	2.19ppb
1,1,2,2 Tetrachloroethane	1	0.240	nd
1,2,3 Trichloropropane		0.150	nd
n-Propylbenzene		0.230	nd
Bromobenzene		0.300	nd
1,3,5 Trimethylbenzene		0.240	nd

Parameter/Method VOC/EPA 524.2	MCL (ug/L)	MDL (ug/L)	Result (ug/L)
Chlorotoluene-2		0.210	nd
Chlorotoluene-4		0.200	nd
tert-Butylbenzene		0.420	nd
1,2,4 Trimethylbenzene		0.230	nd
sec-Butylbenzene		0.230	nd
p-Isopropyltoluene		0.260	nd
1,3 Dichlorobenzene	600	0.260	nd
1,4 Dichlorobenzene	75	0.310	nd
n-Butylbenzene		0.250	nd
1,2 Dichlorobenzene	600	0.340	nd
1,2 Dibromo-3-Chloropropane		0.250	nd
1,2,4 Trichlorobenzene	9	0.250	nd
Hexachlorobutadione		0.250	nd
Naphthalene	300	0.170	nd
1,2,3 Trichlorobenzene		0.260	nd
Total Xylenes	1000	0.440	nd

MCL = Maximum Contaminant Level **MDL** = Minimum Detection Level
nd = none detected **ug/L** = **ppb** (parts per billion) ****** = Exceeds **USEPA** limits

Remarks:

All parameters tested meet the requirements established by the **USEPA**.

Report Date: **January 2, 2009**

By: **Thomas J. Mullen**
Laboratory Director